2021 JUN -1 AM 8: 59



2020 CERTIFICATION

Consumer Confid	ence Report (CCR)	
1319EX 1391	104 Water	H 550C.
	System Name	
074007	<u> </u>	
-	Water Systems included in this CCR	evolen and distribute a Consumer
The Federal Safe Drinking Water Act (SDWA) requires each Commu Confidence Report (CCR) to its customers each year. Depending on the customers, published in a newspaper of local circulation, or prove procedures when distributing the CCR.	e population served by the PWS, this C	CR must be mailed or delivered to
CCR DISTRIBUTION (C	theck all boxes that apply.)	
INDIRECT DELIVERY METHODS (Attach copy of publication, is	ब्रेड्स ्थार्स (भार विदेशका)	DATE (SSUED
□ Advertisement in local paper (Attach copy of advertisement)	2700	
√ On water bills (Attach copy of bill)		
□ Email message (Email the message to the address below)		
□ Other	i i	
DIRECT DELIVERY METEOD (Attach con) of publication water	hill-oj-strien	āvang rednikā:
□ Distributed via U. S. Postal Mail		
Distributed via E-Mail as a URL (Provide Direct URL): _ https://r	nsrwa.org/2020ccr/BlackBayou	<u> 1.pdf</u>
□ Distributed via E-Mail as an attachment		
□ Distributed via E-Mail as text within the body of email message		
$\hfill \square$ Published in local newspaper (attach copy of published CCR o	r proof of publication)	
□ Posted in public places (attach list of locations)		
□ Posted online at the following address (Provide Direct URL).		
I hereby certify that the CCR has been distributed to the custom above and that I used distribution methods allowed by the SDW and correct and is consistent with the water quality monitoring of	 A. I further certify that the informat 	ion included in this CCR is true
Water Super.	Serretary	5-27.21 Date
Name //	(Select one method ONLY)	Date
You must email, fax (not preferred), or mail a	•	n to the MSDH.
Mail: (U.S. Postal Service)	Email: water.reports@msdh.ms	
MSDH, Bureau of Public Water Supply	, ————————————————————————————————————	
P.O. Box 1700	Fax: (601) 576-7800	(NOT PREFERRED)

2020 Annual Drinking Water Quality Report 2021 MAY 19 AH 🐉 10 Black Bayou Water Association PWS#: 0760076 May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Cockfield Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Black Bayou Water Association have received a moderate ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Earline Wolford 662.686.7150. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for the first Monday in January at 10:00 AM at the Black Bayou Water Office.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picod	curies per lite	er is a measur	e of the radioactivity in	water.				
				TEST RESU	JLTS				
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of	Contamination
Radioactive	e Conta	minant	S						
6. Radium 226 Radium 228	N	2020	.40 .79	No Range	pCi/L	0		5 Erosion of natu deposits	
Inorganic (Contam	inants							
8. Arsenic	N	2020	1.7	.6 – 1.7	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass an electronics production wastes	
10. Barium	N	2020	.0315	.00170315	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
13. Chromium	N	2020	8.9	1.4 – 8.9	ppb	100	100	Discharge from steel and pulp mills erosion of natural deposits	

14. Copper	N	2018/20	0	0		ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.721	.33721		ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	0	0	0		(AL=15	Corrosion of household plumbing systems, erosion of natural deposits
20. Nitrite (as Nitrogen)	N	2020	.03	.021503		ppm 1 1		1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	2020	3	No Range	No Range		50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	2019*	230000	98000 - 23000	00	ppb	0		Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Volatile On 76. Xylenes	ganic	Contam 2020	inants .00133	.00093700	133	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
Disinfectio	n By-I	Products							
81. HAA5	N	2020	31	5 - 28	ppb		0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2020	58	3.36 – 71.9	ppb		0	80	By-product of drinking water chlorination.
Chlorine	N	2020	1.1	0 – 9	ppm		0 1	ARDL = 4	Water additive used to control

^{*} Most recent sample. No sample required for 2020.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississispip State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Black Bayou Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

P.	LACK BAYO O. BOX 916 ELAND, MS		OC. DSWW	View and pay y	our bills online	Pre-Sorted	Mail		
METER READ	04/15/2021 30500		USAGE 8600 gal	at www.ub-pay municipal code	is BBDSW	U.S. Postage Paid LELAND, MS 38756			
Prior Balance Payment(s) Voided Payment(s) Water				47.15 -47.15 -47.15 65.30	DUE	Permit #11			
Lat	e Fee		BKA	4.72	DATE ACCT. 06/15 NO. 1610 BILL DATE 05/2:	SRV. TYPE	117:17 124:17 Residential		
Tot	al Due			117.17		INEDY FLAT	RD		
DUE DATE 06	/15/2021	12	4.17	RETURN THIS STUR WITH PAYMENT	ACCT. NO. 16	AMT. DUE	117.17		
AV htt aci AV	AILABLE ON p://www.msr kBayou.pdf / AILABLE AT	wa.org/2020ccr/B A COPY IS THE WATER				RANTON DY FLAT RD S 38756-9576	;		
OF	FICE. 686-71	50.		* ** * **					

յունդիվնոլդներիորդիվիութիկութիների հերոնդիկուների հերինի